

# FIRE DOOR CHECKLIST



**Fire door  
Keep shut**

# FIRE DOOR CLOSER

- Check closer for damage, wear and leaks
- Ensure door closes in under 25 seconds
- Verify door latches when opened 5° (75mm)
- Confirm CE/UKCA certification present
- Check power size meets EN3 minimum
- Ensure concealed closers have intumescent protection
- Test electromagnetic holders release with fire alarm

# FIRE DOOR GAPS & SEALS


- Check frame-door gap is 2-4mm
- Verify correct intumescent strips fitted on perimeter
- Ensure strips remain continuous around hardware
- Inspect strips for wear and tear
- Confirm threshold gap meets manufacturer's guidelines



# FIRE DOOR HINGES

- Confirm minimum of 3 hinges per door
- Check each hinge has CE/UKCA mark and fire stamp
- Verify all hinges properly secured with correct screws
- Ensure hinge grade suits fire door requirements
- Check intumescent pads installed as per test evidence

# FIRE DOOR LEAF & FRAMES

- 
- Check door for visible damage or wear
  - Verify frame is fully intact
  - Ensure any modifications comply with manufacturer's guidance



LAST  
BUT  
NOT  
LEAST



# FIRE DOOR SIGNAGE

- Check doors have correct signage on both sides
- Ensure all signs comply with BS4599 standard

Fire doors save lives by containing fire and smoke spread within buildings.

Regular checks and servicing maintain their effectiveness. Ensure your fire safety compliance with proper door inspections alongside thorough Risk Assessments.

Don't compromise on safety—protect your occupants by keeping fire doors in perfect working order.



# FIRE SAFETY MADE SIMPLE, AFFORDABLE AND EFFECTIVE.

---

OHEAP's expert team delivers complete protection without complexity.

To arrange your fire door inspection, contact OHEAP Fire and Security on 0330 999 8786 or [marketing@oheap.co.uk](mailto:marketing@oheap.co.uk)

#FireSafety #ExpertAdvice



SAVE FOR LATER

